



BILLS OF QUANTITIES			
NO	DESCRIPTION	UNIT	QUANTITY
1	CONCRETE BLOCKS 150mm x 230mm x 460mm	NO	2200
2	CEMENT	Bags	360
3	SAND	m3	39
4	AGGREGATES	m3	85
5	REINFORCEMENT		
	16mm	Kg	1872
	12mm	Kg	0
	10mm	Kg	1249
	X.P.M SHEET 120mm x 240mm	PCS	25
6	BITUMEN	Litres	37

1. A BLINDING LAYER OF CONCRETE TO BE LAID OVERSITE BEFORE CASTING FOUNDATIONS AND SLAB
2. MAIN HORIZONTAL: LAP TO BE 762mm ON ALL WALL STEEL
3. COVER TO MAIN BARS ON ROOF SLAB TO BE 38mm MIN.
4. UNLESS OTHERWISE STATED CONC MIX TO BE 1:2:4
5. ALL PARTS OF LADDER TO BE RUSTPROOF
6. BITUMEN JOINTS 1 VOL FLINKATE TYPE 1 OR 3 , 2 VOL CLEAR SAND CAST IN 2 LAYERS AND HAMMERED TIGHT
7. DESIGN STRESSES : CONCRETE 57.8kg/cm² IN STEEL 1406.14
8. EXTERNAL LADDER TO BE PROVIDED

[illegible]

Item#	Quantity	Title/Name, designation, material, direction etc		Article No./Reference
Designed by	Checked by	Approved by -	date	File name
			14/01/2020	Scale
MINISTRY OF WATER				
S/MO/843				Sheet 1/7